2020 JUN 18 AMII: 18

## 2019 CERTIFICATION

Consumer Confidence Report (CCR)

SUNNY DAKS WATER ASSW.

Public Water System Name

List PWS ID #s for all Community Water Systems included in this CCR

0550008

The Federal Safe Drinking Water Act (SDWA) requires each Community Public Water System (PWS) to develop and distribute a Consumer Confidence Report (CCR) to its customers each year. Depending on the population served by the PWS, this CCR must be mailed or delivered to the customers, published in a newspaper of local circulation, or provided to the customers upon request. Make sure you follow the proper procedures when distributing the CCR. You must email, fax (but not preferred) or mail, a copy of the CCR and Certification to the MSDH. Please check all boxes that apply.

	Customers were	e informed of availability of CCR by: (Attach	copy of publication	, water bill	or other)	
		☐ Advertisement in local paper (Attach co)	py of advertisement,	)		
		☐ On water bills (Attach copy of bill)				
		☐ Email message (Email the message to the	he address below)			
		☐ Other				
	Date(s) custo	mers were informed: // /2020	/ /2020	1	/2020	
<b>V</b>	CCR was distr methods used	ributed by U.S. Postal Service or other dir	rect delivery. Must	specify oth	ner direct o	lelivery
	Date Mailed/	Distributed: 6 115120				
	CCR was distri	buted by Email (Email MSDH a copy)	Date Emailed:	/ /2	020	e e
		☐ As a URL		(Pr	ovide Direc	t URL)
		☐ As an attachment				
		☐ As text within the body of the email mes	ssage			
	CCR was publi	shed in local newspaper. (Attach copy of public	lished CCR <u>or</u> prooj	f of publica	tion)	
	Name of Nev	vspaper:				
	Date Publishe	ed:/				
	CCR was poste	ed in public places. (Attach list of locations)	Date Pos	sted:/	/ 2020	
	CCR was poste	ed on a publicly accessible internet site at the f	following address:			
				(Pre	ovide Direc	t URL)
I here above and co of He	e and that I used di orrect and is consistant, Bureau of Pu A le/Title (Board Pre	sident, Mayor, Owner, Admin. Contact, etc.)  Submission options (Select one	to the PWS officials b	pation including the Mississi  A  Date	ed in this CC ippi State De	K is true
	<b>Mail:</b> (U.S. MSDH. Burea	Postal Service) au of Public Water Supply	Email: water.rep	orts( <u>a</u> )msdh.	.ms.gov	

CCR Deadline to MSDH & Customers by July 1, 2020!

P.O. Box 1700

Jackson, MS 39215

**Fax:** (601) 576 - 7800

\*\*Not a preferred method due to poor clarity \*\*

## 2019 Annual Drinking Water Quality Report Sunny Oak Water Association PWS#: 550008

May 2020

2020 JUN 18 3411: F8

We're pleased to present to you this year's Annual Quality Water Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water.

If you have any questions about this report or concerning your water utility, please contact Joseph Werner at 601.310.4077. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the second Thursday of the month at 6:00 PM at the water office located at 138 Floyd Moody Rd. Poplarville, MS 39470.

Our water source is from wells drawing from the Miocene Aquifer. The source water assessment has been completed for our public water system to determine the overall susceptibility of its drinking water supply to identified potential sources of contamination. A report containing detailed information on how the susceptibility determinations were made has been furnished to our public water system and is available for viewing upon request. The wells for the Sunny Oak Water Association have received a lower susceptibility ranking to contamination.

We routinely monitor for contaminants in your drinking water according to Federal and State laws. This table below lists all of the drinking water contaminants that we detected during the period of January 1st to December 31st, 2019. In cases where monitoring wasn't required in 2019, the table reflects the most recent results. As water travels over the surface of land or underground, it dissolves naturally occurring minerals and, in some cases, radioactive materials and can pick up substances or contaminants from the presence of animals or from human activity; microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm-water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm-water runoff, and residential uses; organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations and septic systems; radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some contaminants. It's important to remember that the presence of these contaminants does not necessarily indicate that the water poses a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Maximum Contaminant Level (MCL) - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) - The "Goal" (MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL) - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary to control microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG) - The level of a drinking water disinfectant below which there is no known or expected risk of health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Parts per million (ppm) or Milligrams per liter (mg/l) - one part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000

TEST RESULTS									
Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measure -ment	MCLG	MCL	Likely Source of Contamination	

Inorganie	c Conta	aminant	S				200	n u	11 10	APEN	
8. Arsenic	N	2019	7	No Range		ppb	202	n/a	10	Erosion of natural deposits; runoff from orchards; runoff from glass and electronics production wastes	
10. Barium	N	2019	.035	,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,	1	ppm		2	2		
14. Copper	N	2015/1	7* .5	0		ppm		1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives	
16. Fluoride	N	2019	.201	199201		ppm		4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories	
17. Lead	N	2015/1	7* 6	0		ppb		0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits	
Disinfecti	ion By-	Product	ts								
Chlorine	N	2019	1.2	.53 – 1.2	mg/l		0	MDRL = 4		Water additive used to control microbes	
Unregula	ted Co	ntamina	nts								
Sodium	N	2019	52000	41000 - 52000	PPB	N	ONE			Road Salt, Water Treatment Chemicals, Water Softeners and Sewage Effluents.	

<sup>\*</sup> Most recent sample. No sample required for 2019.

As you can see by the table, our system had no violations. We're proud that your drinking water meets or exceeds all Federal and State requirements. We have learned through our monitoring and testing that some contaminants have been detected however the EPA has determined that your water IS SAFE at these levels.

We are required to monitor your drinking water for specific contaminants on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. In an effort to ensure systems complete all monitoring requirements, MSDH now notifies systems of any missing samples prior to the end of the compliance period.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our water system is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at http://www.epa.gov/safewater/lead. The Mississippi State Department of Health Public Health Laboratory offers lead testing. Please contact 601.576.7582 if you wish to have your water tested.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1.800.426.4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline 1.800.426.4791.

The Sunny Oak Water Association works around the clock to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.